

§ 420.17

such systems generate an increased effluent volume.

(c) *Beehive cokemaking* [Reserved].

§ 420.17 Effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional technology (BCT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional technology.

(a) *By-product cokemaking—iron and steel.*

SUBPART A

Pollutant or pollutant property	BCT effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kkg (pounds per 1,000 lb) of product	
TSS	0.253	0.131
O&G	0.0327	0.0109
pH	(¹)	(¹)

¹ Within the range of 6.0 to 9.0.

(1) Increased loadings, not to exceed 11 percent of the above limitations, are allowed for by-product coke plants which have wet desulfurization systems but only to the extent such systems generate an increased effluent volume.

(2) Increased loadings, not to exceed 27 percent of the above limitations, are allowed for by-product coke plants which include indirect ammonia recovery systems but only to the extent that such systems generate an increased effluent volume.

(b) *By-product cokemaking—merchant.*

40 CFR Ch. I (7–1–00 Edition)

SUBPART A

Pollutant or pollutant property	BCT effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Kg/kkg (pounds per 1,000 lb) of product	
TSS	0.270	0.140
O&G	0.0348	0.0116
pH	(¹)	(¹)

¹ Within the range of 6.0 to 9.0.

(1) Increased loadings, not to exceed 10 percent of the above limitations, are allowed for by-product coke plants which have wet desulfurization systems but only to the extent such systems generate an increased effluent volume.

(2) Increased loadings, not to exceed 25 percent of the above limitations, are allowed for by-product coke plants which include indirect ammonia recovery systems but only to the extent that such systems generate an increased effluent volume.

(c) *Beehive cokemaking.* No discharge of process wastewater pollutants to navigable waters.

Subpart B—Sintering Subcategory

§ 420.20 Applicability; description of the sintering subcategory.

The provisions of this subpart are applicable to discharges and to the introduction of pollutants into publicly owned treatment works resulting from sintering operations conducted by the heating of iron bearing wastes (mill scale and dust from blast furnaces and steelmaking furnaces) together with fine iron ore, limestone, and coke fines in an ignition furnace to produce an agglomerate for charging to the blast furnace.

§ 420.21 [Reserved]

§ 420.22 Effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must